

Comparison Table – “Fuel Storage and Distribution” (General Regulations)

Current Zoning Bylaw No. 2498, 2012	Proposed Zoning Bylaw No. 3065, 2024
<p>Fuel Storage and Distribution</p> <p>.1 In the RS1, RS2 and RSM1 zones, the placement and maintenance of fuel storage tanks exceeding 50 litres shall be prohibited, except where the tank is used only for storing heating fuels; and</p> <p>.2 All fuels distribution pumps or devices shall be located a minimum of 3.5 metres from any parcel line.</p>	<p>Fuel Storage and Distribution</p> <p>.1 In the Low Density Residential zones, the placement and maintenance of fuel storage tanks exceeding 50 litres is prohibited, except where the tank is used only for storing heating fuels; and</p> <p>.2 All fuel distribution pumps or devices shall be located a minimum of 3.5 metres from any parcel line.</p>

NOTE: In Zoning Bylaw No. 2498, 2012, the regulations for “Fuel Storage and Distribution” is found at Section 7.24. In Draft Zoning Bylaw No. 3065, the regulations for “Fuel Storage and Distribution” are found at Section 6.3.

DRAFT